

ANNOUNCEMENT

The Management of Rwanda Energy Group Limited (REG) wishes to inform its esteemed customers that on **Saturday, 28th July** from **8:00am** to **11:00am** there will be a planned power outage in District of Nyamagabe and Nyaruguru then in Maraba and Karama Sectors in Huye District, due to the Maintenance and repair works on Rukarara 2 Medium Voltage electricity line (30kV).


The Management of REG regrets any inconveniences that may be caused by this activity and appreciates your full cooperation.

Done at Kigali, on

18 JUL 2018

Ron Weiss

Ron WEISS
Chief Executive Officer



ITANGAZO

Ubuyobozi bukuru bwa sosiyete ishinzwe ingufu mu Rwanda (REG) buramenyeshya abafatabuguzi bayo ko **kuwa Gatandatu** taliki ya **28 Nyakanga 2018** kuva saa **Mbiri** za Mugitondo (**8h00**) kugeza saa **tanu** (**11h00**) z'amanywa hateganyijwe ibura ry'amashanyarazi mu Turere twa **Nyaruguru, Nyamagabe n'Imirenge ya Maraba na Karama** yo mu **karere ka Huye**, kubera imirimo yo gusana umuyoboro w'amashanyarazi wa **Rukarara 2**.


Abantu bose barasabwa kwitondera insinga z'amashanyarazi kuko umuriro ushobora kugaruka mbere y'isaha yavuzwe haruguru.

Twiseguye ku bafatabuguzi bacu kubera ibura ry'umuriro rizaba mu gihe cy'iyo mirimo.

Bikorewe i Kigali kuwa **18 JUL 2018**

Ron Weiss

Ron WEISS
Umuyobozi Mukuru



OUTAGES ACTIVITIES PLAN

Project: MAINTENANCE WORKS ON RUKARARA FEEDER

Location	Dates	Requirement	Works to be done	
Rukarara 2			Team 1	Team 2
Kizi and Maraba	28th July, 2108	Three hours	Replacement of 3 Surge Arrestors defective on tower holding disconnect switch of Kizi and 1 at Maraba Coffee transformer	Replacement of damaged Air-break of line disconnect switch known as Entrée Butare
Nzega, Bugarama and Gako	28th July, 2108	3Hours	Repairing of line disconnect switch called NZEGA and Replacement drop out at Bugarama	Replacement of the tension insulator broken at tower number 110 (Gako place towards Maraba)
Nyamugali and Kibeho	28th July, 2108	3Hours	Cut the big trees which are above MV line identified at Nyamugali /Gatyazo	Removal of bird's nests in the pylons number 35,39 and 41 all located in Kibeho sector, and replacement of broken insulator observed on the pylon number 44 located Nyange Village, Nyarushishi / Kibeho
Gihindamuyaga and Sovu	28th July, 2108	3Hours	Removal all bird's nests observed in the towers from Gihindamuyaga toward Huye Sector and in the tower beside Magerwa office	Replacement of Surge Arrestor defective on SOVU Monasterie's transformer and repairing Disconnect switch of Huye Sector transformer
Kadahokwa	28th July, 2108	3Hours	Cut the big trees around MV line at IPRC forest (Trees located at 500 meters) and others observed at Kadahokwa water treatment plant toward Ryakibogo transformer (Trees located at 600 meters)	

Prepared by:

Jean de Capistran MUSHINZIMANA
A.g RSE Southern